

FIRE SAFETY CERTIFICATE

No.

Date: 24/06/2024

Certified that the **L P SAVANI RIVERSIDE SCHOOL, DABHOLI** at Ved - Dabholi road, Dabholi, Surat Gujarat-395004. Comprised of Basement + Ground Floor + 4 Floors Occupied by the L P SAVANI RIVERSIDE SCHOOL, DABHOLI managed by Ramdev Education & Medical Trust have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT fire services Rules, and verified by the officers concerned of fire services on 15/02/2024 in the presence of Mr. Ghanshyambhai Pavasiya President of L P SAVANI RIVERSIDE SCHOOL, DABHOLI managed by Ramdev Education & Medical Trust and that the building / premises is fit for occupancy up to classes XII with effect from 15/02/2024 for a period of 2 years in accordance with rule and subject to compliance of the conditions as appended.

Renewal

1. This certificate issued by FSO as per rules and regulation of Gujarat government gazette dated 13-12-2023 for Act- Gujarat Fire Prevention & Life Safety Measures Act, 2013 (Guj. Act No. 11 of 2013)
2. Mr. Nikunj J. Padsala (FSO-A) is registered FSO. This certificate is issued after dual physical verification on site and as per norms by FSO.
3. The Fire Safety Certificate is renewed for a period of two (2) years up to 14/02/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

Issued on 15/02/2024 FSCR No: FSCA/O/CFOSMC/2021/00003116/R1

Sign & Stamp of FSO With License No.

Nikunj Padsala
FSOA/2021/001237



Dabholi 24/06/2024
I/C Dy. Chief Fire Office
Fire & Emergency Department
Surat Municipal Corporation

To,
The Principal
L P SAVANI RIVERSIDE SCHOOL
Ved- Dabholi Road, Dabholi
Surat Gujarat-395009

ENDORSEMENT

The no objection certificate issued by Fire Services stand cancelled and annulled due to any violation of the state Fire Services Rules.



FORM B 13.3
FIRE SAFETY CERTIFICATE RENEWAL (FSCR)
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOSMC/2021/00003116
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOSMC/2021/00003116/R1

Date: 15/02/2024

Building Occupancy/Category: Educational (non-residential)

To,

BHAVESHBHAI GOLAKIYA
VED - DABHOLI ROAD AT DABHOLI SURAT. SURAT SURAT CITY Surat MC 395004
Fire Region: Surat MC
Mobile No: 9909788443 Email ID: vrundevcorporation@gmail.com

This has reference to your Application No. **2024/00046900** dated 03/02/2024 for **Fire Safety Certificate Renewal (FSCR)** for the building/premise **L.P. SAVANI RIVERSIDE SCHOOL (name of the Building/ Project)**, as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: SURAT CITY
5. Name of Block(s): L P SAVANI RIVERSIDE SCHOOL

The building/premise was inspected on **15/02/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **15/02/2024**
2. Six monthly inspection was done on **15/02/2024**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **15/02/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Nikunj Padsala
Fire Safety Officer - Advance (FSO-A)
2021/001237

Date: 15/02/2024
Time: 10:28 AM



FSCA/O/CFOSMC/2021/00003116/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.