




No.PHD/PI/૨૨૬  
Dt.૩૧/૦૭/૨૦૨૪

**SAFE DRINKING WATER AND SANITARY CONDITION**

**CERTIFICATE**

It is certified that an inspection team headed by Mr. J.P.Raval, Sanitary Inspector from Health Department inspected L. P. Savani Riverside School, situated at T.P.S.No.51(Dabholi), F.P.No.27, Near KumKum Farm, Ved Road, Dabholi, Surat on Dt.05/07/2024 and found that the **L. P. Savani Riverside School** has Safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the State govt.

The above is valid for a period of one year from the Date of issue.

  
**Dr. Pradeep H. Umrigar**  
Medical Officer of Health  
Health Department  
Surat Municipal Corporation

To,  
Principal  
L. P. Savani Riverside School,  
T.P.S.No.51(Dabholi),  
F.P.No.27, Near KumKum Farm,  
Ved Road, Dabholi,  
Surat.





## Public Health Laboratory

Surat Municipal Corporation  
2<sup>nd</sup> Floor, Vesu Urban Community Health Center  
Opp. Vesu Fire Station, VIP Road,  
Vesu, Surat - 395007 Gujarat

Name And Address of Applicant-	L.P Savani Riverside School, Dabholi.			Report No.	No.Q-1/PHL/WC/B-1669/2023-24
				Receipt No.	389122
				ULR No.	-
				Date of Sample	02/02/2024
Type of Sample:-	Private	Register Entry No.	1669	Start Date of Analysis	03/02/2024
Source of the Water:-	Drinking Water			End Date of Analysis	03/02/2024

### Test Report

**Sample Description :-** A plastic bottle

**Physical Appearance:-** Clear Liquid

**Loose**

Sr. No.	Quality Characteristic Test	Name of Method of test used	Unit	Result	Prescribed std. as per Regulations No. 2.10.9 & as per provision of the Act, Rules & Regulations
1.	Colour	FSSAI Manual of Method-2016 Water Section A Method No.I.1.	Hazen unit	1	Max.5
2.	Taste	FSSAI Manual of Method-2016 Water Section A Method No.I.4.	-	Agreeable	Agreeable
3.	Odour	FSSAI Manual of Method-2016 Water Section A Method No.I.2.	-	Agreeable	Agreeable
4.	pH Value	FSSAI Manual of Method-2016 Water Section A Method No.I.3.	-	7.4	6.5 To 8.5
5.	Ammonia (as Total Ammonia-N)	FSSAI Manual of Method-2016 Water Section A Method No.II.1.	mg/l	Absent	Max. 0.5
6.	Nitrate (as NO <sub>3</sub> )	FSSAI Manual of Method-2016 Water Section A Method No.II.4	mg/l	Absent	Max. 45
7.	Chlorides (as Cl)	FSSAI Manual of Method-2016 Water Section A Method No.II.5.	mg/l	35.0	Max. 250
8.	Total Alkalinity (as Calcium Carbonate)	FSSAI Manual of Method-2016 Water Section A Method No. II.9.	mg/l	50.0	Max. 200
9.	Total hardness (as CaCO <sub>3</sub> )	FSSAI Manual of Method-2016 Water Section A Method No.II.8.	mg/l	25.0	Max.200
10.	Total Dissolved Solids	FSSAI Manual of Method-2016 Water Section A Method No.I.6.	mg/l	110.0	Max. 500

**Opinion:** With respect to the test and observation performed, above sample of **Drinking Water** conforms to the standards and provisions of Food Safety and Standard Act. 2006 and FSS Rules & Regulations.

.....end of the test report.....

Report issue Date :-05/02/2024



Food Analyst  
Public Health Laboratory  
Surat Municipal Corporation  
Surat

Note:-

- ❖ Sampling is not carried out by our authority therefore, the result contained on this report relate only to the sample material tested.
- ❖ Sample drawn by party. Report is meant for guidance only. It is not valid for any litigation or Publicity purpose.